

East Contra Costa



Fire Protection District

DEMO

F.D. Permit Number _____

_____ Date

Description of Work: _____

Project Name: _____ Address: _____ Suite _____

City: _____ Zip: _____ Additional Info. _____

Company: _____ Address: _____

Contact Person: _____ Phone No. () _____ Lic# / Type _____

City: _____ State: _____ Zip: _____ Email _____

APPLICATION SECTION: DO NOT MARK BELOW THIS LINE

We have reviewed the proposed **demolition plans** for the project facility. Our review is to insure compliance with the minimum code requirements related to fire and life safety as set forth in the California Fire Code. The following selected comments shall apply to this project:

- Submit two (2) copies of automatic fire sprinkler system plans and specifications, as prepared by a C-16 licensed fire sprinkler contractor, which conform to NFPA 13, as amended, for review and approval prior to system modification. CFC 903.2
- Submit two (2) copies of fire alarm system plans, calculations, and specifications, as prepared by a C-7 or C-10 licensed contractor, which conform to NFPA 72 – 2016, as amended, for review and approval prior to system modification. CFC 907.1.1
- Required means of egress shall be maintained during construction and demolition, remodeling or alteration and additions to any building. CFC 3311.2
- Structures under construction, alteration or demolition shall be provided with not less than one portable fire extinguisher in accordance with Section 906 and sized for not less than ordinary hazard as follows: CFC 3315
 1. At each stairway on all floor levels where combustible materials have accumulated.
 2. In every storage and construction shed.
 3. Additional portable fire extinguishers shall be provided where special hazards exist including, but not limited to, the storage and use of flammable and combustible liquids.
- Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container. CFC 3304.4
- Temporary heating devices shall be listed and labeled in accordance with the California Mechanical Code. Installation, maintenance and use of temporary heating devices shall be accordance with the terms of the listing. CFC 3303.1

(CONTINUED OVER)

Fee computed by: _____

Amount Due: _____

Received by: _____

Amount Received: _____

Cash Credit Check No. _____

Invoice No. _____

- Temporary wiring for electrical power and lighting installations used in connection with the construction, alteration, or demolition of buildings, structures, equipment, or similar activities shall comply with the California Electrical Code. CFC 3304.7
- Operations involving the use of cutting and welding shall be done in accordance with Chapter 35 of the CFC. CFC 3304.6
- Fire watch required. Qualified personnel shall be provided to serve as an on-site fire watch. Fire watch personnel shall be provided with at least one **approved** means for notification of the fire department and their sole duty shall be to perform constant patrols and watch for the occurrence of fire. CFC 3304.5
- The owner shall designate a person to be the fire prevention program superintendent who shall be responsible for the fire prevention program and ensure that it is carried out through completion of the project. CFC 3308.1
- The fire prevention program superintendent shall be responsible for supervising the permit system for hot work operations in accordance with Chapter 35 in the Fire Code. CFC 3308.5
- Coverings placed on or over fire protection devices to protect them from damage during construction processes shall be immediately removed upon the completion of the construction processes in the room or area in which the devices are installed. CFC 3308.7
- Additional comments: _____

- Approved plans **shall** be onsite at time of inspection. Failure to have approved plans onsite may result in the **cancellation of the inspection**, and a **reinspection fee** being assessed.
- Contact the Fire District at **925-240-2139** (minimum **two** working days notice required) to schedule an onsite inspection. No inspections will be scheduled on Fridays.

On the morning of the inspection, a confirmation telephone call made to the Fire District at 925-240-2139 is necessary between 8:00 and 8:30 AM. Otherwise, the inspection will be cancelled.

Final acceptance may be subject to field inspections.

Approval does not relieve the designer / contractor from complying with all applicable fire code requirements, nor does it abrogate the requirements of other authorities having jurisdiction.

Approved as submitted. Approved with Comments. Denied, Resubmittal Required.

Reviewed by: _____ Date: _____